



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 3722	1-Aug-2022	Number 2	Issue date 4-Aug-2022	30-Apr-2024

Product designation

Anka, AJ Series, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, wireless interconnectable, photoelectric smoke alarms

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Anka Sci-tech Co., Limited
4fl, J building, No.1, North Area, Shangxue Tech Park Bantian, LONGGANG DISTRICT, SHENZHEN, GUANGDONG, CHINA, 518129

Registrant

Anka Sci-tech Co., Limited
4fl, J building, No.1, North Area, Shangxue Tech Park Bantian, LONGGANG DISTRICT, SHENZHEN, GUANGDONG, CHINA, 518129

Producer

Anka Sci-tech Co., Limited
4fl, J building, No.1, North Area, Shangxue Tech Park Bantian, LONGGANG DISTRICT, SHENZHEN, GUANGDONG, CHINA, 518129

Conformance criteria and evaluation

The Anka, AJ Series, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, wireless interconnectable, photoelectric smoke alarms have been evaluated and verified as conforming with the relevant requirements of the following criteria.

- i. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015) / Amdt 2 (30 October 2018).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the Compatibility of this equipment with new or existing actuating devices should be verified prior to installation.

- i. Conformity of the "TUYA Smart" application, as described in WiFi Interconnected Smoke Alarm User Guide, is not included within the scope of this certification.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 3722	1-Aug-2022	Number 2	Issue date 4-Aug-2022	30-Apr-2024

Producer's description

The Anka, Model AJ-Series, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, wireless interconnectable, photoelectric smoke alarms are low profile, circular styled, 3 Vdc self-contained smoke alarms intended for use in residential dwellings.

This equipment senses smoke using photoelectric principle. An electric buzzer/horn provides an audible alarm signal when the smoke alarm senses smoke which exceeds a predetermined level. When the smoke level drops below the alarm level, the buzzer/horn is de-energised.

A self-test facility is provided by means of a button. If the button is depressed an alarm signal is emitted.

A 'silence button' feature is also incorporated . Pressing the hush button silences the smoke alarm. The smoke alarm will be silent for approximately 10 minutes, at which time the smoke alarm automatically returns to normal operation.

Depending upon the model variant (refer Schedule of variant designations), either a plain mounting base or WiFi smart base is provided.

The wireless communication interface interconnects up to a maximum of 22 devices.

Technical specification

The following details are a representative extract of the technical specification for the Anka, AJ Series, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, wireless interconnectable, photoelectric smoke alarms and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Type	Variant Ident.	Description	Base type
Model	AJ-760SI	Wireless interconnectable, photoelectric smoke alarm	Plain mounting base
	AJ-760SI-W		WiFi Smart Base
	AJ-761SI		Plain mounting base
	AJ-761SI-W		WiFi Smart Base
	AJ-762SI		Plain mounting base
	AJ-762SI-W		WiFi Smart Base
	AJ-763SI		Plain mounting base
	AJ-763SI-W		WiFi Smart Base
	AJ-765SI		Plain mounting base
	AJ-765SI-W		WiFi Smart Base

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Sensor	Photoelectric (Type A)
Power	Built-in 3 Vdc (CR123A) Lithium battery Battery not user replaceable
Alarm volume	> 85 dB(A) at 3 meters.
Hush time	approx. 10 minutes
Wireless interconnection	up to 22 detectors
Sound pattern	ISO7731

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 3722	1-Aug-2022	Number 2	Issue date 4-Aug-2022	30-Apr-2024

Page 3 of 3

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3511/R1	Evaluation for Conformity of Anka Sci-Tech Co. Ltd AJ Series Photoelectric Smoke Alarms to the requirements of AS 3786:2014 +A1 +A2	6-Jul-2022	CSIRO, Fire Systems Laboratory, AU
Document	Manual for wifi & Interconnected smoke alarm AJ-76XSI-W_Ver 1.0_22-0613.pdf	WIFI Interconnected Smoke Alarm User's Guide Model: AJ-760SI-W, AJ-761SI-W, AJ-762SI-W, AJ-763SI-W, AJ-765SI-W (Manual for wifi & Interconnected smoke alarm AJ-76XSI-W_Ver 1.0_22-0613.pdf)	16-Jun-2022	Anka Sci-Tech Co. Ltd, CN