




C-Bus Eight and Twelve Channel Voltage Free Relay Installation Instructions

55xxRVF Series














Table of Contents

Sec	ction	Page
1.0	Product Range	3
2.0	Description	3
3.0	Capabilities	3
4.0	Compatible Loads	3
5.0		
6.0	Connection to the C-Bus Network	5
7.0	C-Bus DIN Rail Series Relay Features	5
7	'.1 Local Override Buttons	
-	7.2 Remote Override Facility	
8.0	,	
9	0.1 C-Bus Indicator	
•	0.2 Unit Indicator	
	0 C-Bus System Clock	
	0 C-Bus Network Burden	
12.0	0 Power-Up Load Status	8
13.0	0 C-Bus Power Requirements	9
	0 Stand-Alone Programming	
	Power Surges and Short Circuit Conditions	
	0 Megger Testing	
	0 Standards Complied	
	0 Programming Requirements	
	0 Important Warning	
	0 Mechanical Specifications	
21.0	0 Electrical Specifications	12

Copyright Notice

© Copyright 2004 Clipsal Integrated Systems Pty Ltd. All rights reserved.

Trademarks

- Clipsal is a registered trademark of Clipsal Australia Pty Ltd.
- C-Bus and C-Bus2 are registered trademarks of Clipsal Integrated Systems Pty Ltd.
- Intelligent Building Series is a registered trademark of Clipsal Integrated Systems Pty Ltd.

All other logos and trademarks are the property of their respective owners.

Disclaimer

Clipsal Integrated Systems reserves the right to change specifications or designs described in this manual without notice and without obligation.

1.0 Product Range

L5508RVF Eight Channel Voltage Free Relay, with C-Bus Power Supply (220-240V, 50-60 Hz)

L5508RVFP Eight Channel Voltage Free Relay (220-240V, 50-60 Hz)

LE5508TRVF Eight Channel Voltage Free Relay, with C-Bus Power Supply (110-120V, 50-60 Hz)

LE5508TRVFP Eight Channel Voltage Free Relay (110-120V, 50-60 Hz)

L5512RVF Twelve Channel Voltage Free Relay, with C-Bus Power Supply (220-240V, 50-60 Hz)

L5512RVFP Twelve Channel Voltage Free Relay (220-240V, 50-60 Hz)

LE5512TRVF Twelve Channel Voltage Free Relay, with C-Bus Power Supply (110-120V, 50-60 Hz)

LE5512TRVFP Twelve Channel Voltage Free Relay (110-120V, 50-60 Hz)

2.0 Description

The 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay products are C-Bus output devices, designed to be used in a switchboard application. Either eight or twelve independent voltage free relay contacts are provided for general switching applications. For ease of installation they are DIN rail mounted, measuring 12M wide (1M = 17.5 +0.5/-0.0 mm) wide. C-Bus connection is conveniently achieved through the use of RJ45 connectors, allowing similar units to be quickly looped together.

3.0 Capabilities

The 55xxRVF Series products have an internal C-Bus power supply capable of supporting a number of other C-Bus units (200mA capacity). All units with a suffix "P" do not have a C-Bus power supply, but consume no current from the C-Bus Network during normal operation.

These units also generate a C-Bus system clock signal, therefore providing all the support necessary for a simple C-Bus Network. Local toggle buttons are provided on each unit to allow individual channels to be toggled at each unit or via C-Bus commands. Remote ON and OFF facilities are available, permitting all channels to be turned ON or OFF without C-Bus Network communications. These units isolate mains power from the extra low voltage C-Bus Network.


4.0 Compatible Loads

The 55xxRVF Series Relay units are suitable for use with the following loads:


Load Symbol	Compatible Loads	Load Rating Per Channel
- \ \-	Incandescent lighting Halogen 240V lamps	
====	Fluorescent lighting	
	Resistive load	
	Low voltage lighting with iron-core transformers	
	Low voltage lighting with electronic transformers	
M	Exhaust fans (shaded pole induction motors) * Ceiling fans (split-phase induction motors) *	2A

* The installer must ensure that an appropriate manually operated mechanical isolating switch and circuit breaker is installed with the motor in order to comply with local wiring rules applicable to the region.

5.0 Wiring Instructions



Wiring for 5508RVF Series Model




Wiring for 5512RVF Series Model

NOTE:

- The unit is capable of handling up to either eight or twelve channels of 10A switched active loads. The installer should make adequate consideration for the total current consumption when selecting power feed cables. It is recommended that multiple feed cables to be allowed for. Each feed cable must have an appropriate MCB to protect that load circuit.
- A maximum of 10 C-Bus DIN Rail units (with 200mA power supply) can be connected to a single C-Bus Network. A maximum of 100 "P" suffix units may be interconnected.
- The installer must fix mains cables in the distribution board using cable ties or trunking as required by local wiring rules. Care must be taken not to allow copper strands to enter the DIN unit's apertures.
- A maximum torque of 1.4Nm should be applied to the mains rated screw terminals.
- Rubber bungs are supplied (3 off) for unused RJ45 connectors, to stop foreign bodies from entering the unit. Always ensure these bungs are installed when the unit is to be mounted inside a mains rated enclosure.
- Use copper wire only

6.0 Connection to the C-Bus Network

Installation requires connection to the unshielded twisted pair C-Bus Network Cable. The illustration opposite shows the recommended technique for cable termination giving the best electrical performance. It is required that Category 5 data cable is used, Clipsal catalogue number 5005C305B.



RJ Pin	C-Bus Connection	Colour
1	Remote ON	Green/White
2	Remote ON	Green
3	C-Bus Neg (-)	Orange/White
4	C-Bus Pos (+)	Blue
5	C-Bus Neg (-)	Blue/White
6	C-Bus Pos (+)	Orange
7	Remote OFF	Brown/White
8	Remote OFF	Brown

NOTE:

- It is recommended that the Remote Override (On/Off) connections be maintained for correct operation of these services across the C-Bus Network, even if they are not intended to be used. Remote Override services may be disabled in software if necessary.
- A Clipsal RJ5CB300PL Cat UTP patch cord is included with the unit for easy interconnection. No more than 10 x 55xxRVF Series products should be connected to one physical C-Bus Network. This may be extended to 100 for "P" suffix units.
- Rubber bungs are supplied (3 off) for unused RJ45 connectors, to stop foreign bodies from entering the unit. Always ensure these bungs are installed when the unit is to be mounted inside a mains rated enclosure.

7.0 C-Bus DIN Rail Series Relay Features

7.1 Local Override Buttons

The buttons located on the front of the unit provide a means to toggle each channel locally (at the unit). Each button is illuminated when the respective channel is in the On state.

Operation	Function
Short Press	One short press will toggle the state of this channel only
Double Click	Two short presses within 2 seconds will return this channel only to the C-Bus Network level
Long Press	Pressing any of the Local Override buttons for longer than 2 seconds will return all channels to the C-Bus Network level


Note that double-click and long press operations will only occur if the unit/channel is already in override mode. C-Bus commands received by the unit will (by default) override local toggle changes. In this case, only the channel associated with the received commands will revert to the current C-Bus Network state. This option may be disabled in software. Please refer to Section 8.0, Priority of Operating Modes.

7.2 Remote Override Facility

Remote control of all channels on a unit can be achieved via the extra pairs of conductors on the C-Bus connector. The diagram opposite shows switches may be connected in parallel on any one Network, using green and green/white conductors for the remote ON function. Brown brown/white may be wired in the same fashion for remote OFF, with these conductors being connected to C-Bus negative via the switch to action this state. A Clipsal 30/1/2LM mechanism makes an ideal remote input switch.

NOTE:

C-Bus is a balanced network and therefore at any point where C-Bus negative (-) is taken, C-Bus positive (+) must also be present. Hence both network conductors must be looped through all remote input switches on the Network.



8.0 Priority of Operating Modes

The output status of the 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay product can be changed by:

- Pressing a C-Bus Key,
- By activating any of the Local Override buttons or
- By using the Remote Override facilities.

The table below shows the priority ranking of these control inputs,

Mode	Priority	Function
Remote OFF	1 (Highest)	Turns all channels OFF
Remote ON	2	Turns all channels ON
Local Override	3*	Toggle channel
C-Bus Input Unit (Key, PIR etc)	4* (Lowest)	Control the channel

^{*} Local Override has priority over normal C-Bus commands received on the bus (such as those generated by pressing a C-Bus Key). By default, if any channel is in Local Override mode and a C-Bus command is received for that channel, the C-Bus command state will be imposed ("Enable C-Bus Priority" option). This feature can be disabled in software so all relevant C-Bus commands will be ignored by the unit when it is in Local Override Mode.

For further information about the programming this and other C-Bus units, please refer to the C-Bus Technical Manual (5000S/2, 5000M/2).

9.0 Status Indicators

9.1 C-Bus Indicator

This indicator shows the status of the C-Bus Network at this unit. If sufficient network voltage and a valid C-Bus Clock signal are present then the 'OK' signal will be displayed (continuous green light). If a Network is connected which has more current load than the power supplies can support, then this indicator will flash to show a marginal Network voltage. If there is no C-Bus Clock present then this indicator will not light. When the unit is powered from C-Bus only, for stand-alone programming, this indicator will not function.

Indicator Status	Meaning
On	Power on and functional
Flashing	Insufficient power to support Network
Off	No C-Bus Clock signal present;
	No mains connected

Further debugging of possible Network problems can be achieved with the Clipsal C-Bus Network Analyser tool (5100NA).

9.2 Unit Indicator

This indicator shows the status of the individual unit. When mains is supplied to the unit, 'OK' will be displayed (continuous green light). If any of the channels have been toggled (using Override facilities) into a state other than is present on the C-Bus network, this indicator will flash with a 90% ON duty cycle. This applies to either Local or Remote Override inputs. When the unit is powered from C-Bus only for stand-alone programming, this indicator will not function.

Indicator Status	Meaning
On	Normal operation
Flashing	Unit in override mode
Off	No mains connected

10.0 C-Bus System Clock

The 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay product incorporates a software selectable C-Bus System Clock. The System Clock is used to synchronise data communications waveforms on a C-Bus Network. At least one active C-Bus System Clock is required on each C-Bus Network for successful communications. No more than three units on any C-Bus Network should have Clock circuitry enabled, so this option should normally be disabled using the C-Bus Installation Software.

If a System Clock is required, it can be enabled from the 'Global Tab' on the Graphical User Interface (GUI) for the unit.

11.0 C-Bus Network Burden

The 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay product incorporates a software selectable Network Burden. The Network Burden can be enabled using the C-Bus Installation Software.

A Network Burden may or may not be required to ensure correct operation of the C-Bus Network. If in doubt, consult the C-Bus Calculator (Network Design Verification Software Utility) before proceeding with the hardware installation.

CAUTION:

The Graphical User Interface (GUI) software is designed to prevent the Burden from accidental selection. The following steps are required to correctly enable the Network Burden from the GUI:

- 1. Set the Unit Address to '001';
- 2. Turn to the 'Global Tab' of the GUI;
- 3. Select the Network Burden check box (cross inside box for ON);
- 4. Click the OK button;
- 5. Select 'Save to Network' and/or 'Save to Database';
- 6. Click the OK button; then
- 7. Repeat steps 3 and 4 within 20 seconds, to save your selection.

To disable the Network Burden the same process applies except the Burden selection check box is cleared (remove cross).

Important Note:

Always disable all 5100PC Interface Network Burdens before installing C-Bus DIN range products, which include a power supply (non "P" suffix versions). If a burden is required, use the built-in burden on the DIN Rail unit only.

12.0 Power-Up Load Status

All C-Bus units have onboard non-volatile memory, which is used to store the operating state of the unit in case of power loss. The 55xxRVF Series products incorporate latching relays and will retain their current output status if C-Bus power is lost. On restoration of power the DIN Rail Relay unit initiates a short power-up diagnostic routine, which lasts for approximately 5 seconds. User programmable options will then allow the relay status to be set as desired.

For further information about the programming this and other C-Bus units, please refer to the C-Bus Technical Manual (5000S/2, 5000M/2).

13.0 C-Bus Power Requirements

The 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay is available in several different configurations. All variants draw 18mA from the C-Bus Network when not connected to the mains supply. With mains connected, these units draw no current from the C-Bus Network.

In addition, a unit whose catalog number does not include a "P" suffix (such as the L5508RVF or L5512RVF) can supply up to 200mA to the Network when it is connected to the mains. "P" suffix variants (such as the L5508RVFP or L5512RVFP) do not include the 200mA power supply.

Adequate C-Bus Power Supply Units must be installed to support the connected devices. If in doubt, consult the C-Bus Calculator (Network Design Verification Software Utility) before proceeding with the hardware installation.

14.0 Stand-Alone Programming

The 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay products can be programmed without a mains connection. The unit can be connected to any operational C-Bus Network that is capable of supporting one or more extra C-Bus units (18mA current required). The unit can then be configured using the C-Bus Installation Software. Indicators and relays will only function when a mains connection is made.

15.0 Power Surges and Short Circuit Conditions

The mains voltage must be limited to the range specified for any unit which is mains powered. Each Unit incorporates transient protection circuitry. Additional external power surge protection devices should be used to enhance system immunity to power surges. It is strongly recommended that overvoltage equipment such as the Clipsal 970 be installed at the switchboard.

16.0 Megger Testing

Megger testing must never be performed on the C-Bus data cabling or terminals as it may degrade the performance of the Network.

Megger testing of mains wiring of an electrical installation that has C-Bus Units connected will not cause any damage to C-Bus Units. Since C-Bus Units contain electronic components, the installer should interpret megger readings with due regard to the nature of the circuit connection.

17.0 Standards Complied

DECLARATIONS OF CONFORMITY

European Directives and Standards

Model L55xxRVF Series comply with the following:



European Council Directive		Standard	Title
89/336/EEC	EMC Directive	IEC/CISPR 14; EN 55014	RFI Emissions Standard
		IEC61000-3-2; EN61000-3-2	Low Frequency Emissions
		EN 61000-4-2	Immunity to ESD
		EN 61000-4-3	Immunity to RFI
		EN 61000-4-4	Immunity to EFT
		EN 61000-4-5	Immunity to Surge Voltages
		EN 61000-4-11	Immunity to Voltage Dips and
			Interruptions
		IEC 60669-2-1	Particular Requirements for
			Electronic Switches – EMC clause
97/32C/EEC	Low Voltage	IEC 60669-2-1	Particular Requirements for
	Directive		Electronic Switches – Safety clause
		IEC 61558-1	Transformer Safety Standard
		IEC 61558-2-17	Transformer Safety Standard

Australian/New Zealand EMC & Electrical Safety Frameworks and Standards

Model L55xxRVF Series comply with the following:



	Regulations	Standard	Title
	EMC (C-Tick)	AS1044	RFI Emissions Standard
)		AS/NZS 61000-3-2	RFI Emissions Standard
	Electrical Safety	AS/NZS 3100	General Requirements for Electrical Equipment
	•	AS/NZS 3108; IEC 742	Requirements for Safety Extra Low Voltage

U.S. and Canadian Product Safety Standards and U.S. FCC Regulations

Model LE55xxTRVF Series comply with the following:



	Standards/Regulations	Title
	CSA C22.2 No. 14	Industrial Control Equipment
s	UL508	Industrial Control Equipment
ı	Tested to FCC Standards	FCC Part 15
	for Home or Office Use	ANSI C63.4

Supplemental Information

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesirable operation

Class B Product

NOTE:

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encourage to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna
- Increase the separation between the equipment and receiver
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected
- Consult the dealer or an experienced radio/TV technician for help

Warning: Any changes or modifications not expressively approved by Clipsal Integrated Systems could void the user's authority to operate this equipment.

18.0 Programming Requirements

The 55xxRVF Series C-Bus 8 and 12 Channel Voltage Free Relay must be programmed to set a unique identification (Unit Address) and mode of operation on the C-Bus Network. C-Bus Installation Software v2.2.0 (or higher) can be used to configure the:

- Project Name
- Part Name
- Unit Address
- Clock (Enable/Disable)
- Network Burden (Enable/Disable)
- Relay Switching Relationships
- Other Advanced Operating Parameters (e.g. Logic Relationships, Turn-On Thresholds, Power Fail Options etc).


The C-Bus Installation Software can be downloaded from the Clipsal Integrated Systems Web Site (www.clipsal.com/cis).


For further information about the programming this and other C-Bus units, please refer to the C-Bus Technical Manual (5000S/2, 5000M/2).

19.0 Important Warning

The use of any non-approved software in conjunction with the hardware installation without the written consent of Clipsal Integrated Systems may void any warranties applicable to the hardware.

20.0 Mechanical Specifications





No user serviceable parts inside.

Note: - Both the 8 and 12 channel models have the same dimensions.

- (Shown above is a 12 channel model)

21.0 Electrical Specifications

Catalogue No.	L5508RVF / L5512RVF	L5508RVFP / L5512RVFP	LE5508TRVF / LE5512TRVF	LE5508TRVFP / LE5512TRVFP
Nominal Supply Voltage	220-240V~		110-120V~	
Frequency Range(s)	47-53Hz and 57-63Hz			
C-Bus Supply Voltage	15-36V DC @ 18mA required for programming when mains is not connected. Sources 200mA to the C-Bus Network with mains connected.	15-36V DC @ 18mA required for programming when mains power is not connected. 15-36V DC @ 0mA required for programming when mains power is connected. Does not source current to the C-Bus Network.	15-36V DC @ 18mA required for programming when mains is not connected. Sources 200mA to the C-Bus Network with mains connected.	15-36V DC @ 18mA required for programming when mains power is not connected. 15-36V DC @ 0mA required for programming when mains power is connected. Does not source current to the C-Bus Network.
AC Input Impedance	50kΩ @1kHz A maximum of 10 units may be connected on a single C-Bus Network	100kΩ @1kHz A maximum of 100 units may be connected on a single C-Bus Network	50kΩ @1kHz A maximum of 10 units may be connected on a single C-Bus Network	100kΩ @1kHz A maximum of 100 units may be connected on a single C-Bus Network
Electrical Isolation	3.75kV RMS from C-Bus to	Mains		
Status Indicators	C-Bus Indicator Voltage ≥ 20V DC Voltage < 20V DC Voltage < 15V DC Unit Status Indicator On Flashing Off Load Indicators (8 or 12) Load indicator is On when	Clock Present On Flashing Off Mains Power Present Present Fail	No Clock Present Off Off Off Off Conditions Normal Operations At least one channel in Local or Remote Override mode Mains power not available	
Max. Number of Units on a Single C-Bus Network	10	100	10	100
Load Rating Resistive Inductive Fluorescent Motor Switch Operations	10A 10A 10A 2A Greater than 60,000 operations at rated load (see above for load types)			
Contact Type	Voltage Free, Magnetically	Latched		
Quiescent Power	10 Watts			
Warm Up Time	5 seconds			
Restart Delay	0 seconds to 42 minutes ar	nd 30 seconds		
Network Clock	Software selectable			
Network Burden	Software selectable	25 v 2 56 ih\		
Dimensions Remote Override	215 x 85 x 65mm (8.46 x 3 Remote switch input can be daisy chained to a maximum of 10 units and a maximum of 1000m of cable	Remote switch input can be daisy chained to a maximum of 100 units and a maximum of 1000m of cable	Remote switch input can be daisy chained to a maximum of 10 units and a maximum of 1000m of cable	Remote switch input can be daisy chained to a maximum of 100 units and a maximum of 1000m of cable
Mains Terminals		² or 1 x 2.5mm ² (2 x 16 AWG	or 1 x 13 AWG)	·
Weight	L5508RVF/LE5508TRFV: 525g (19 oz), L5508RVFP/LE5508TRVFP: 725g (26 oz), L5512RVF/LE5512TRVF: 600g (21 oz), L5512RVFP/LE5512TRVFP: 800g (28 oz)			
C-Bus Connections	RJ45 sockets			
Remote Override Connection	RJ45 sockets			
Operating Temp. Range	0-45°C (32 - 113°F)			
Operating Humidity Range	10 – 95% RH			

NOTES:

Further Information

For further information about configuring this product and other C-Bus devices, please consult the documentation supplied. Further assistance can be obtained as follows:

C-Bus Manuals

The 5000M/2 C-Bus Technical Manual provides a comprehensive and definitive guide to Clipsal C-Bus. Includes hardware and software specifications, product datasheets, system design and installation guides, and software overview with fully worked programming examples.

C-Bus Installation Software

The 5000S/2 C-Bus Installation Software (includes 5000M/2 C-Bus Technical Manual) may be used to unlock the power and flexibility of Clipsal C-Bus. Unit operation may be completely customised to suit user requirements. Advanced control functions may be programmed.

C-Bus Installer Training Courses

Contact your nearest Clipsal Integrated Systems Sales or Technical Support Officer and enquire about Clipsal C-Bus Installer Training and Certification Programs today!!

Technical Support and Troubleshooting

For further assistance, please consult your nearest Clipsal Integrated Systems Sales Representative or Technical Support Officer.

Technical Support Hotline
Technical Support Email
Sales Support Email
Clipsal Integrated Systems Website

1 300 722 247 (Australia Only) techsupport.cis@clipsal.com.au sales.cis@clipsal.com.au clipsal.com/cis

Products of Clipsal Integrated Systems Pty Ltd

ABN 15 089 444 931

Head Office

12 Park Terrace, Bowden South Australia 5007

International Phone +61 8 8440 0500
International Fax +61 8 8346 0845
Internet clipsal.com/cis
E-Mail cis@clipsal.com.au